



AEP ANALYTICAL CHEMISTRY SERVICES

Analysis Report

02004
502 North Allen Ave.
Shreveport, LA 71101
Phone: (318) 673-3802
Fax: (318) 673-3960

Report ID : 37267	Company: AEP - Canton (AK)	Address: 5300 Navarre Rd., S.W., 01 Canton, OH 44706
Date Received: 03/08/2018	Contact: Phone: (330) 580-5142	

SampleID	Customer SampleID	Parameter	Value	Unit	DLim	D/C	Method	Matrix	Serial #	Type Man/Equip	Size	Sample Description	Codes	Location	Collected By	Collected Date	Analysis Date	Tech
214670	001	PCB Oil	< 1	mg/kg	1	1	A 8082A 2	Oil				CUNO		12994		3/6/2018	3/16/2018	SFP

Quality Control Data

* Quality control units are the same as reported analytical results

Date	Parameter	Sample ID	Blank Value	Standard			Spike			Surrogate % Recovery	Duplicate % Difference	Tech
				Value	Recovery	%	Value	Recovery	%			
3/16/2018	PCB- Aroclor 1254	214669					15.82	17.763	112.3	97.0		SFP
3/16/2018	PCB- Aroclor 1260	214670								98.0	0.0	SFP
3/16/2018	PCB- Aroclor 1260			50	55	110.0						SFP
3/16/2018	PCB Oil		0									SFP

Laboratory Manager

Wednesday, March 21, 2018
Report Date